

DWCo. LTD

Dufferin Water Co. LTD
13 Rose Ridge Lane
Mono On
L9W 5Y3
Phone 519 942 5695 Fax 519 940 3956

27 March 2018

Maple Leaf Acres Tenants Association
R.R. No. 4
Fergus Ontario
N1M 2W5

Re: Water Sample Results

To Whom it May Concern:

Dufferin Water Co. Ltd conducts weekly testing of the treated (potable) water that is supplied to the residents of Maple Leaf Acres. All of the testing conducted in 2018 and up to and including the samples collected until March 27, 2018 indicate that the water meets or exceeds all of the chemical and microbiological standards mandated in the Safe Drinking Water Act with the exception of sodium.

Sodium is tested once every 5 years with the last test conducted on May 02, 2016. This sample returned a result of 23 mg/L. The standard for sodium is 20 mg/L for individuals on a sodium restricted diet. For those not on a sodium restricted diet the standard is 250 mg/L. To put the sodium levels into context consuming 2 litres (8 glasses) of MLA water would add 46 mg of sodium to your diet. For comparison a single slice of bread contains from 170 to 450 mg of sodium.

If you have any questions please call.

Regards,

A handwritten signature in blue ink, appearing to read 'Joe Miedema', with a long horizontal flourish extending to the right.

Joe Miedema P. Eng.
General Manager